

## TEST REPORT

TO: Community Action Head Start  
2475 Center ST NE  
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

### Collection Information

Date: 06/15/2017  
Time: 0815  
By: Salinas/Kelley  
Lab #: 20170620-074  
Location: Indy Pre K 1

### Lab Receipt Information

06/20/2017  
1101  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0111		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL  
SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed  
EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA  
MRL-"Method Reporting Limit"

\* Accreditation  
A- Waterlab Corporation, ORELAP 100039  
The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Head Start  
2475 Center ST NE  
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

### Collection Information

Date: 06/15/2017  
Time: 0815  
By: Salinas/Kelley  
Lab #: 20170620-075  
Location: Indy Pre K-2

### Lab Receipt Information

06/20/2017  
1101  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0046		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Community Action Head Start  
2475 Center ST NE  
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

### Collection Information

Date: 06/15/2017  
Time: 0815  
By: Salinas/Kelley  
Lab #: 20170620-079  
Location: Indy EHS K

### Lab Receipt Information

06/20/2017  
1101  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0029		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Head Start  
2475 Center ST NE  
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

### Collection Information

Date: 06/15/2017  
Time: 0815  
By: Salina/Kelley  
Lab #: 20170620-076  
Location: Indy EHS 1

### Lab Receipt Information

06/20/2017  
1101  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0021		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Head Start  
2475 Center ST NE  
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

### Collection Information

Date: 06/15/2017  
Time: 0815  
By: Salina/Kelley  
Lab #: 20170620-077  
Location: Indy EHS 2

### Lab Receipt Information

06/20/2017  
1101  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Community Action Head Start  
2475 Center ST NE  
Salem, OR 97301

07/10/2017

COMACTHS

PO#: 24962

### Collection Information

Date: 06/15/2017  
Time: 0815  
By: Salinas/Kelley  
Lab #: 20170620-078  
Location: Indy EHS 3

### Lab Receipt Information

06/20/2017  
1101  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0021		0.001	mg/l	0.020	06/29/2017	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

